

Non-tech fail

Water "control" fail

Ctrl valve 1 fail

Ext.temp < 0C

Partially/wholly closed

PIV  
closed/obstructed

Alarm / check  
valve fail

Too little H2O to sprinkler  
system

Pipe failure (not  
defined)

Obstruction  
between sprinkler  
& fire